


# EC type-examination Certificate

Number **T10360** revision 0  
Project number 11200271  
Page 1 of 1

Issued by	NMi Certin B.V., designated and notified by the Netherlands to perform tasks with respect to conformity modules mentioned in article 9 of Directive 2004/22/EC, after having established that the Measuring instrument meets the applicable requirements of Directive 2004/22/EC, to:
Manufacturer	ABB AB / Cewe-Control Arnöleden 2 SE-611 31 Sweden
Measuring instrument	A static <b>Active Electrical Energy Meter</b> Type : C11 Reference voltage : 230 V Reference current : 5 A Destined for the measurement of : electrical energy, in a - single-phase two-wire network Accuracy class : A or B Environment classes : M2 / E2 Temperature range : -40°C / +70 °C  Further properties are described in the annexes – Description T10360 revision 0 – Documentation folder T10360-1
Valid until	27 January 2022

Issuing Authority **NMi Certin B.V., Notified Body number 0122**  
27 January 2012

  
C. Oosterman  
Head Certification Board

**NMi Certin B.V.**  
Hugo de Grootplein 1  
3314 EG Dordrecht  
The Netherlands  
T +31 78 6332332  
certin@nmi.nl  
www.nmi.nl

This document is issued under the provision  
that no liability is accepted and that the  
applicant shall indemnify third-party liability.

The designation of NMi Certin B.V. as Notified  
Body can be verified at [http://  
ec.europa.eu/enterprise/newapproach/nando/](http://ec.europa.eu/enterprise/newapproach/nando/)

Parties concerned can lodge  
objection against this decision,  
within six weeks after the date of  
submission, to the general manager  
of NMi (see [www.nmi.nl](http://www.nmi.nl)).

Reproduction of the complete  
document only is permitted.