



Current Transformer Test Block

Summary

Test Blocks are used during the installation of Current Transformer and/or Voltage Transformer operated meters.

Testing facilities are required by some Code of

Product Code

Availability
Type
No of Terminals
Aperture

MATB

Next Day
CT/VT Test Block
13

6.0 mm cable terminals


Practice applications (<u>click here</u> for more information). They dictate that testing facilities should be available and close to the meter. The facilities enable the meter to be routinely tested and/or changed safely with the primary supply circuit energised. The Test Blocks enable just that, the operator can short circuit the CT to either test or change the meter.

Specification

- Facilitates easy & safe in-situ testing of C.T operated metering systems without disrupting load circuit
- High electrical strength

- Robust Construction
- Robust transparent cover
- 1100 V.50A
- Large diameter for cable entry (6mm)

Dimensions



Additional Images



